COMPLIANCE SCHEDULE DETAILS: SS 1 - AUTOMATIC SYSTEMS FOR FIRE SUPPRESSION (E.G. SPRINKLER SYSTEM)



| PLEASE PROVIDE THE FOLLOWING INFORMATION | | | | | Date: | | | | |
|---|------------------------|---|--|----------------------|-----------------------|--|----------------------|-------|--|
| If you need help to complete this form, consult the system provider or an IQP who is registered for the system above. | | | | | | | | | |
| Applicant name: | | | | | Building name: | | | | |
| Site address: | | | | | Classified Use: | | | | |
| Existing Compliance Schedule Number(s): (if applicable) | | | | | Risk/purpose group: | | | | |
| () () () () () () () () () () | | | | | Fire hazard category: | | | | |
| | | | | | Total occupant load: | | | | |
| | | | | | | | | | |
| SPECIFIED SYSTEM DESCRIPTION (ADDRESS THOSE ITEMS THAT APPLY) | | | | | | | | | |
| Specified systems: | | | Existing Ne | | | Modified Moved | | Moved | |
| Type: | | | Type 6 or Type 7 | | | | | | |
| | | | Gas flood fire suppression system installed with a building for computer equipment protection. | | | | | | |
| | | | Other: (specify) | | | | | | |
| Location pl | lan for specifie | d systems a | nd records is | attached: Yes | s No | | | | |
| No. Ec | No. Equipment location | | Make (main com | | nponents) | Model | | | |
| 1 | | | | | | | | | |
| 2 | | | | | | | | | |
| 3 | | | | | | | | | |
| 4 | | | | | | | | | |
| STANDA | RDS (ADDR | RESS THO | SE ITEMS T | HAT APPLY) | | | | | |
| | | | | | alled against a s | specific Stan | ndard(s) / document. | | |
| Performano installation: | ce/ N | igned solutions do not apply if the system has been insta NZS 4541:2020 Automatic fire sprinkler systems | | | | | | | |
| motaliation. | | NZS 4541:2013 Automatic fire sprinkler systems | | | | NZS 4515:2003 Fire sprinkler systems for residential occupancies. | | | |
| | N. | NZS 4541:2007 Automatic fire sprinkler systems | | | | NZS 4515:1995 Fire sprinkler systems for residential occupancies (including private dwellings) | | | |
| | N. | NZS 4541:2003 Automatic fire sprinkler systems | | | | NZS 4515:1990 Residential fire sprinkler systems. | | | |
| | N. | NZS 4541:1996 Automatic fire sprinkler systems | | | | Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is | | | |
| | N | NZS 4541:1987 Automatic fire sprinkler system | | | 5. | competent to do so. (Details provided). | | | |
| | | ZS 4541P:197 stallations. | 72 NZ rules for | automatic fire sprir | nkler | Other: | | | |

STANDARDS (ADDRESS THOSE ITEMS THAT APPLY)

 $Specifically \ designed \ solutions \ do \ not \ apply \ if \ the \ system \ has \ been \ installed \ against \ a \ specific \ Standard(s) \ / \ document.$

| Inspections: | NZS 4541:2020 Part 12, Clause 12.3 to 12.4 | NZS 4541: 2013 Part 12, Clause 1203 to 1204 | | | | | |
|--------------|---|---|--|--|--|--|--|
| | NZS 4515:2009 Part 8, Clause 8.2 | AS 1851: 2012 Sections 1 to 14 | | | | | |
| | AS ISO 14520.1:2009 Part 9 | | | | | | |
| | Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided) | | | | | | |
| | Other: | | | | | | |
| Maintenance: | NZS 4541:2020 Part 12, Clause 12.1 to 12.7 | NZS 4541:2013 Part 12, Clause 1201 to 1207 | | | | | |
| | NZS 4515:2009 Part 8 | AS 1851:2012 Sections 1 to 14 | | | | | |
| | AS ISO 14520.1:2009 Part 9 | | | | | | |
| | Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided) | | | | | | |
| | Other: | | | | | | |

INSPECTIONS, MAINTENANCE AND REPORTING (ADDRESS THOSE ITEMS THAT APPLY)

| Minimum inspection and maintenance procedures: | Planned preventative inspection, maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection Standard/document, to ensure the system will operate as required in the event of a fire. |
|--|--|
| Equipment requiring weekly maintenance: | Building contains diesel fire pump Building contains an electric fire pump without an alarm |
| Inspection & Maintenance - frequency and responsibility: | Depending on the type of installation and its performance standard/document: Specifically designed solutions: by IQP only Standard /Standard /another document: Monthly: by IQP only Annually: by IQP only |
| Inspections & Maintenance: | Annual Inspection: The system is connected to the building's emergency warning system therefore testing of the interface between the two systems will be carried out annually. The system is NOT connected to the building's emergency warning system. |
| Reporting: | The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the on-site log book or electronically, which will remain available with the most recent compliance schedule, and as a minimum include: Details of any inspection, test or preventative maintenance carried out, including dates, works undertaken, faults found, remedies applied and the person who performed the work. Form 12A provided annually by the IQP. |