

Date:

### PLEASE PROVIDE THE FOLLOWING INFORMATION

If you need help to complete this form, consult the system provider or an IQP who is registered for the system above.

| Applicant name:   | Building name:        |
|---|-----------------------|
| Site address:   | Classified Use:       |
| Existing Compliance Schedule Number(s): (if applicable) | Risk/purpose group:   |
|   | Fire hazard category: |
|   | Total occupant load:  |

## **SPECIFIED SYSTEM DESCRIPTION** (ADDRESS THOSE ITEMS THAT APPLY)

| Specifi   | ed systems:        | Existing | New                    | Modified | Removed |
|---|--------------------|----------|------------------------|----------|---------|
| Type:   |                    |          |                        |          |         |
| Location plan for specified systems and records is attached: Yes No |                    |          |                        |          |         |
| No.   | Equipment location |          | Make (main components) | Model    |         |
| 1   |                    |          |                        |          |         |
| 2   |                    |          |                        |          |         |
| 3   |                    |          |                        |          |         |
| 4   |                    |          |                        |          |         |
| 5   |                    |          |                        |          |         |

# STANDARDS (ADDRESS THOSE ITEMS THAT APPLY)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

| Performance/<br>installation: | IEC 60118-4:2014+AMD1:2017 CSV electroacoustics. Hearing aids. Induction-loop systems for hearing aid purposes. System performance requirements    |
|-------------------------------|--|
|                               | AS 60118.4-2007 hearing aids magnetic field strength in audio-frequency induction loops for hearing aid purposes                                   |
|                               | AS 1088.4:1987: Hearing aids. magnetic field strength in audio-frequency induction loops for hearing aid purposes                                  |
|                               | BS EN IEC 60118.4:2015+A1:2018 electroacoustics. hearing aids. Induction-loop systems for hearing aid purposes. System performance requirements    |
|                               | Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided). |
|                               | Other:   |

#### **STANDARDS** (ADDRESS THOSE ITEMS THAT APPLY)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

| Inspections: | IEC 60118-4:2014<br>AS 60118-4:2007<br>Other:            | Specifically designed solution prepared by a person<br>who, on the basis of experience and qualifications,<br>is competent to do so. (Details provided) |
|--------------|--|---|
| Maintenance: | IEC 60118-4 Ed. 3.1 b(2017)<br>AS 60118.4:2007<br>Other: | Specifically designed solution prepared by a person<br>who, on the basis of experience and qualifications,<br>is competent to do so. (Details provided) |

### **INSPECTIONS, MAINTENANCE AND REPORTING** (ADDRESS THOSE ITEMS THAT APPLY) Minimum inspection and Regular inspections and planned preventative maintenance and responsive maintenance will be carried maintenance procedures: out in accordance with the nominated standard/document to ensure continued effective operation of the system during occupation of the building. Inspection frequency Depending on the type of installation and its performance standard/document: and responsibility: Specifically designed solutions: by IQP only Standard /other document: Six-Monthly: by IQP only Inspections & maintenance: As a minimum, these inspections will include the inspection and testing of: six monthly inspections Magnetic field strength in the specified magnetic field area for the values defined in AS 60118.4 Magnetic background noise interference from other equipment, where since the last inspection, equipment has been installed, activated or altered in the proximity of the tele loop system. (Such equipment could include electrical fittings, heating systems, electrical controls or equipment, an adjacent loop system or metallic structures.) Sound amplification installations consisting of loop systems will be tested for sound pressure level and sound distortion. Where room acoustics have been altered since the last inspection, the sound amplification installation will also be tested for spectrum analysis and speech intelligibility. (Room acoustics could have been altered or affected by such things as the addition or removal of carpet, curtains or objects.) The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 Reporting: months. These will be recorded in the on-site log book or electronically, which will remain available with the most recent compliance schedule, and as a minimum include: Details of any inspection, test or preventative maintenance carried out, including dates, works undertaken, faults found, remedies applied and the person who performed the work. Form 12A provided annually by the IQP.